

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-0992:120 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Napco, 333 Bayview Ave., Amityville, NY 11701
Contact: *Edmund Gregorian (631) 842-9400 Fax (631) 842-2726

DESIGN: Models FW-PULL1 and FW-PULL1K noncoded fire alarm manual pull stations; and Model FW-PULL2 Mod station adapter. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC, 1A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed electrically and functionally compatible fire alarm control units.

XLf: 7150-1477:101

*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 20, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager